APP. TYPE	QTY
LX-300G	1





BOILER FOUNDATION





NOTE:

1) DIMENSIONS & SPECIFICATIONS ARE SUBJECT TO CHANGE WITHOUT NOTICE.
2) MINIMUM DIMENSIONS AS SHOW, DO NOT INCLUDE ITEM 2, 5 - 8, 10 & 13.

NO.	NAME OF PART	MATERIAL	QTY	REMARKS / DRAWING #
14	POWER BOX		1	
13	AIR DUCT		1	
12	FEEDWATER PIPING		1	1 1/4"
11	MAIN GAS TRAIN		1	2 1/2"
10	AUTOMATIC BLOWDOWN		1	3/8"
9	MANUAL BLOW-OFF		1	1"
8	MANUAL BLOW-OFF		1	1 1/4"
7	MAIN SAFETY VALVE		2	2" x J x 2 1/2"
6	STEAM OUTLET FLANGE		1	
5	BLOWER		1	
4	CONTROL BOX		1	
3	LIQUID VOLUME CONTROLLER		1	
2	STEAM SEPARATOR		1	
1	BOILER VESSEL		1	

DWN.: S.PENG	CK'D.:	SCALE: NON	DO NOT SCALE
DATE: JULY 12, 2000	APPROVED:	THIRD ANGLE SYSTEM	DIM'N SHOWN ARE INCH
MIURA BOILER CO. LTD. BRANTFORD, ONTARIO, CANADA	DESCRIPTION: BOILER ASS'Y OUTSIDE VIEW		DRAWING NUMBER A000-LX30-0N08

SYM	REVISION	DATE	BY
CAD DWG - NO MANUAL CHANGES PERMITTED			

" CONFIDENTIAL "
THIS MATERIAL IS THE PROPERTY OF MIURA BOILER CO., LTD., AND MUST NOT BE REPRODUCED, PUBLISHED OR DISCLOSED TO OTHERS WITHOUT AUTHORIZATION.